



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilites
 TIME: 6:20
 LOCATION: **Bubbler HS 2nd Flr**

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-02		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilites
 TIME: 6:29
 LOCATION: **HS Kitchen Food Prep**

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
<i>Test Parameters</i>				LAB-ID#: 2051003-19		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	0.003

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382

COLLECTED BY: Facilites
 TIME: 6:20
 LOCATION: HS 1st Flr Bubbler

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

CERTIFICATE OF ANALYSIS

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: <u>2051003-15</u>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilities
 TIME: 6:25
 LOCATION: **HS Bub Elevator 3rd Flr**

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-20		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).

NA = Not Applicable
 ND = Not Detected
 '<' = Less Than
 '*' = Detection Limit

Approved By: **Timothy A. Begley**
 Lab Manager / Date

Digitally signed by Timothy A. Begley
 CN=Timothy A. Begley
 2.5.4.11e
 Date: 2020.09.14 17:06:57

- MCL = Maximum Contaminant Level as adopted by the Commonwealth of Massachusetts and represents the maximum acceptable level in drinking water.
- Recommended limits are suggested levels of materials allowed in water. These may be for aesthetic reasons rather than for human health.
- Currently there are no limits (recommended or mandated) for this parameter. This is merely presented for guidance.
- If present, coliform values (in parentheses) are defined as estimated numbers.



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382

COLLECTED BY: Facilites
 TIME: 6:50
 LOCATION: 2nd Flr Bubbler

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

CERTIFICATE OF ANALYSIS

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-12		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	0.001

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382
 COLLECTED BY: Facilites
 TIME: 6:22
 LOCATION: HS Sink in Nurse

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-14		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).