



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382
 COLLECTED BY: Facilites
 TIME: 7:25
 LOCATION: **DS Kitchen**

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-13		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilites
 TIME: 7:24
 LOCATION: Duval Bubbler by 212

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
-----------	-------------------	---------------	-------	-------------	--	--------

Test Parameters				LAB-ID#: 2051003-17		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382
 COLLECTED BY: Facilites
 TIME: 7:27
 LOCATION: Duval Nurse Behind Desk

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-08		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
 Whitman Hanson School District
 600 Franklin Street
 Whitman, MA 02382

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
 ORDER #: G2051003
 SAMPLE DATE: 9/4/2020
 DATE RECEIVED: 9/4/2020
 SAMPLE ID: Grab
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilites
 TIME: 7:22
 LOCATION: DS Bubbler by Café

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-04		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).