



Ernest Sandland  
 Whitman Hanson School District  
 600 Franklin Street  
 Whitman, MA 02382

**CERTIFICATE OF ANALYSIS**

REPORTED: 09/13/2020  
 ORDER #: G2051003  
 SAMPLE DATE: 9/4/2020  
 DATE RECEIVED: 9/4/2020  
 SAMPLE ID: Grab  
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilites  
 TIME: 7:09  
 LOCATION: IHS Kitchen Food Prep

**RESULTS OF ANALYSIS**

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL <sup>1</sup> / Rec. Limit <sup>2</sup>	Result
<i>Test Parameters</i>				LAB-ID#: <u>2051003-07</u>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 <sup>1</sup>	<b>0.002</b>

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).  
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland  
 Whitman Hanson School District  
 600 Franklin Street  
 Whitman, MA 02382

**CERTIFICATE OF ANALYSIS**

REPORTED: 09/13/2020  
 ORDER #: G2051003  
 SAMPLE DATE: 9/4/2020  
 DATE RECEIVED: 9/4/2020  
 SAMPLE ID: Grab  
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilites

TIME: 6:58

LOCATION: IHS Sink in Nurse Office

**RESULTS OF ANALYSIS**

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL <sup>1</sup> / Rec. Limit <sup>2</sup>	Result
<b>Test Parameters</b>				LAB-ID#: <b>2051003-09</b>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 <sup>1</sup>	<b>0.002</b>

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).  
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland  
 Whitman Hanson School District  
 600 Franklin Street  
 Whitman, MA 02382

**CERTIFICATE OF ANALYSIS**

REPORTED: 09/13/2020  
 ORDER #: G2051003  
 SAMPLE DATE: 9/4/2020  
 DATE RECEIVED: 9/4/2020  
 SAMPLE ID: Grab  
 DESCRIPTION: DRINKING WATER

COLLECTED BY: Facilites  
 TIME: 6:46  
 LOCATION: IHS Bubblers by Café

**RESULTS OF ANALYSIS**

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL <sup>1</sup> / Rec. Limit <sup>2</sup>	Result
<b>Test Parameters</b>				LAB-ID#: <b>2051003-06</b>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 <sup>1</sup>	<b>ND</b>

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).  
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland  
 Whitman Hanson School District  
 600 Franklin Street  
 Whitman, MA 02382

**CERTIFICATE OF ANALYSIS**

COLLECTED BY: Facilites  
 TIME: 6:52  
 LOCATION: IHS Bubbler by 216

REPORTED: 09/13/2020  
 ORDER #: G2051003  
 SAMPLE DATE: 9/4/2020  
 DATE RECEIVED: 9/4/2020  
 SAMPLE ID: Grab  
 DESCRIPTION: DRINKING WATER

**RESULTS OF ANALYSIS**

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL <sup>1</sup> / Rec. Limit <sup>2</sup>	Result
<b>Test Parameters</b>				LAB-ID#: <b>2051003-01</b>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 <sup>1</sup>	<b>0.003</b>

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).  
 Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).